

VAV Mount and Wire Sequence Legend			
For use in the ENVIRO-TEC VAV Selection Program			
XX = Control Manufacturer	X = Actuator Option	X = Heat Type	X = Transformer Option
AA = Automatrix AL = Alerton AN = Andover AU = Auto Logic CR = Carrier CS = CSI DL = Delta HW = Honeywell IV = Invensys JO = Johnson NO = Novar SB = Siebe SM = Siemens ST = Staefa TL = Teletrol	I = Integral Actuator E = Factory Provided Actuator	N = None W = Water Heat E = Electric Heat	E = Factory Provided Transformer F = Field Transformer

Example: **ALINF** = Alerton controls with an integral actuator, no heat and a transformer in the field
 Example: **JOIEE** = Johnson controls with an integral actuator, electric heat and factory provided transformer
 Example: **HWIWE** = Honeywell controls with an integral actuator, water heat and factory provided transformer

Sequences with an asterisk at the end indicate that they do not support more than 2 steps of electric heat without special adds. You must contact the factory for pricing.
 Example: **ALIEE***