



For optimum control accuracy, a straight section of duct at least 1.5 duct diameters long and the same diameter as the inlet collar should be installed upstream of the terminal inlet. Sizes 6 through 22 utilize FlowStar™ multi-axis center averaging sensor; * Sizes 4 and 5 utilize single-axis, linear averaging multi-point sensor resulting in a different line slope as shown above.

TITLE: ΔP vs CFM @ INLET
 FOR MODELS SDR, SGX, DDR, CFR, CFRQ, & VFR
 WITH ENVIRO-TEC® SERIES 7000 ANALOG ELECTRONIC CONTROLS



DRN BY: DVG	DATE: 6/2/08	SCALE: N/A	DRAWING NO.
CKD BY: DB	DATE: 6/2/08	REV: 03	

THIS DRAWING CONTAINS PROPRIETARY DATA.
 UNAUTHORIZED DISCLOSURE, REPRODUCTION, OR USE
 IS STRICTLY PROHIBITED WITHOUT WRITTEN PERMISSION

DO NOT SCALE DRAWING
 DIMENSIONS AND DATA ARE SUBJECT TO CHANGE WITHOUT NOTICE.
 CONTACT FACTORY FOR CERTIFIED DRAWINGS.

15883